#### **Notified Body No. 0832**

## **BRE Global**

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

### Certificate of constancy of performance,

0832-CPR-F1243

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

## ID200 Conventional Class P Heat Detector for use in Fire Detection and Alarm Systems

(For full product details and conditions of use refer to appendix)

Produced by or for

#### Inim Electronics s.r.l

Via Fosso Antico snc – Fraz. Centobuchi 63076 Monteprandone (AP) Italy

and produced in the manufacturing plant(s)

#### Inim Electronics s.r.l

Via Fosso Antico snc – Fraz. Centobuchi 63076 Monteprandone (AP) Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 Heat detectors - Point detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 22 December 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 02 February 2016

Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <a href="mailto:enquiries@breglobal.com">enquiries@breglobal.com</a>.

#### Notified Body No. 0832

# **BRE Global**

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

### Appendix to Certificate of constancy of performance 0832-CPR-F1243

Bases:

EB0010 Standard Base EB0020 Relay Base

**Heat Classifications:** Class B and Class A1R



Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 02 February 2016

Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <a href="mailto:enquiries@breglobal.com">enquiries@breglobal.com</a>.