

Noratel AS

P.O. 133

N-3301 HOKKSUND

Tel: +47 32 25 15 00

Fax: +47 32 25 15 50

firmapost@noratel.no



ISO 9001 Certified

Manufacturer: **Noratel AS – Norway**
Address: **P.O. 133, N – 3301 Hokksund Norway**

herewith declares that:

Type of equipment:

1-Phase; Safety Isolating Transformers

<1000VAC at primary and <50VAC at secondary or <50VDC $\sqrt{2}$ at secondary

Type designation etc.:

**LF60B-XX, LF66A-XX, LF66B-XX, LF78A-XX, LF84A-XX, LF84B-XX, LF96B-XX,
LF96C-XX, LF96CH-XX, LF120C-XX, 150B-XX, LF150C-XX and LF150CH-XX**

Data:

- **25VA 1200VA**

- **Class II • Ambient temp. 40°C •Cooling; AN •Frequency; 47-63Hz**

- **IP2X/IP4X/IP5X • Insul.cl.; E/B**

- **Mobility; stationary or portable • With pri. or sec. cable/plug or sockets**

- *is in conformity with the provisions of the following EC directive(s),
including the latest amendments, and with national legislation implementing this/these directives:*

- 1. Low Voltage Directive 2006/95/EC**
- 2. EMC Directive 2004/108/EC**

and that the following (parts/clauses of) harmonized standards have been applied:

- 1. EN 61558-1:2005+A1:2009 - General requirements
EN 61558-2-6:2009, Particular requirements for Safety isolating transformers for general use.**
- 2. Electromagnetic compatibility acc. to the EMC directive**
The transformer contains no components that generate or are sensitive to electromagnetic disturbances.

- *the following (parts/clauses of) national and/or international technical standards and specifications have been applied:*


N/A

The date of **CE** - marking: **01.01.1996**

Place: **Hokksund**

Date: 14.12.2009

Signature:



Clarification:

Lam Quang Ho

Position:

Design Engineer