



# CERTIFICATE OF CONFORMITY

## CERTIFICATO DI CONFORMITÀ

REGISTRATION No.	<b>1342</b>
NUMERO DI REGISTRAZIONE:	
PRODUCT: PRODOTTO:	<b>CONTROL AND INDICATING EQUIPMENT WITH INTEGRATED POWER SUPPLY EQUIPMENTS ALARM TRANSMISSION AND FAULT WARNING ROUTING EQUIPMENT (optional), ELECTRICAL AUTOMATIC CONTROL AND DELAY DEVICE (optional)</b>
MODEL(S): MODELLO(I):	<b>Series PREVIDIA-Compact</b>
TRADE MARK: MARCA COMMERCIALE:	<b>INIM</b>
APPLICANT: RICHIEDENTE:	<b>INIM ELECTRONICS SRL Via dei Lavoratori 10 – Fraz. Centobuchi – Monteprandone (AP)</b>
MANUFACTURER: COSTRUTTORE:	<b>INIM ELECTRONICS SRL VIA dei lavoratori 10 – Fraz. Centobuchi – Monteprandone (AP)</b>

### TEST RESULTS / RISULTATO DELLE PROVE

A sample of above product was found to be in compliance with the Technical specifications / standards listed below. / Un campione del prodotto specificato è stato provato ed è risultato conforme alle norme / specifiche tecniche qui sotto indicate.

### TEST DETAILS / DETTAGLI DELLE PROVE

TEST REPORT: RAPPORTO DI PROVA:	DATE: DATA:	TECHNICAL SPECIFICATIONS / STANDARDS: SPECIFICHE TECNICHE / NORME DI RIFERIMENTO:
<b>SS18-0026963-01 Rev. 1</b>	<b>2018-11-14</b>	<b>EN 54-13:2017 FIRE DETECTION AND FIRE ALARM SYSTEM – PART 13: COMPATIBILITY AND CONNECTABILITY ASSESSMENT OF SYSTEM COMPONENTS</b>

THIS DOCUMENT IS COMPOSED OF 8 PAGES INCLUDING 1 ANNEX  
QUESTO DOCUMENTO È COMPOSTO DA 8 PAGINE COMPREDENTI 1 ALLEGATO

FIRST ISSUE: PRIMA EMISSIONE	2018-10-10
CURRENT ISSUE: EMISSIONE CORRENTE	2018-11-26
EXPIRES ON: SCADE IL	2021-11-25

B.U. PRODUCT CONFORMITY ASSESSMENT  
DIRECTOR

This Test Certificate is the result of testing a sample of the product submitted, in accordance with the provisions of the specified Technical Specifications / Standards. It is issued according to product certification system 1a of ISO/IEC 17067; therefore, it does not imply any judgment on the production and it does not permit the use of a mark of conformity. Only full reproductions of this Certificate are allowed without written permission of IMQ. / Questo Certificato di Prova è il risultato delle prove effettuate sul campione di prodotto presentato, seguendo le prescrizioni delle corrispondenti norme/ specifiche tecniche citate. Esso è emesso in conformità al sistema di certificazione di prodotto 1a della norma ISO/IEC 17067; pertanto, esso non implica un giudizio sulla produzione e non permette l'uso di un marchio di conformità. Solo la completa riproduzione di questo Certificato è permessa senza l'autorizzazione scritta dell'IMQ.

**1.0 TECHNICAL DATA – GENERAL / DATI TECNICI – GENERALITÀ**

Ratings / Valori: 230 V~ +10% / -15%; 50 Hz (CIE)

**2.0 ADDITIONAL INFORMATION / INFORMAZIONI SUPPLEMENTARI**
**DEVICES LIST UNDER TESTS**

N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
1	INIM ELECTRONICS	Control and indicating equipment	PREVIDIA-C200LZEG	0051-CPR-1498
2	INIM ELECTRONICS	Repeater	PREVIDIA-C-REPEW	0051-CPR-1498/9
3	INIM ELECTRONICS	Repeater	PREVIDIA-C-REPW	0051-CPR-1498/9
4	INIM ELECTRONICS	Repeater	<u>PREVIDIA-C-REPER</u>	0051-CPR-1498/9
5	INIM ELECTRONICS	Repeater	<u>PREVIDIA-C-REPR</u>	0051-CPR-1498/9
6	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200LZER</u>	0051-CPR-1498
7	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200LZG</u>	0051-CPR-1498
8	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200LZR</u>	0051-CPR-1498
9	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200LG</u>	0051-CPR-1498
10	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200LR</u>	0051-CPR-1498
11	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SZEG</u>	0051-CPR-1499
12	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SZER</u>	0051-CPR-1499
13	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SZG</u>	0051-CPR-1499
14	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SZR</u>	0051-CPR-1499
15	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SG</u>	0051-CPR-1499
16	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C200SR</u>	0051-CPR-1499
17	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SZEG</u>	0051-CPR-1499
18	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SZER</u>	0051-CPR-1499
19	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SZG</u>	0051-CPR-1499
20	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SZR</u>	0051-CPR-1499
21	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SG</u>	0051-CPR-1499
22	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C100SR</u>	0051-CPR-1499
23	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SZEG</u>	0051-CPR-1499
24	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SZER</u>	0051-CPR-1499
25	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SZG</u>	0051-CPR-1499
26	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SZR</u>	0051-CPR-1499
27	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SG</u>	0051-CPR-1499
28	INIM ELECTRONICS	Control and indicating equipment	<u>PREVIDIA-C050SR</u>	0051-CPR-1499

<b>Addressable devices</b>				
<b>N.</b>	<b>MANUFACTURER</b>	<b>PRODUCT DESCRIPTION</b>	<b>TYPE</b>	<b>CERTIFICATE N.</b>
29	INIM ELECTRONICS	Smoke detector	ED100	0832-CPR-F1150
30	INIM ELECTRONICS	Heat detector	ED200	0832-CPR-F1244
31	INIM ELECTRONICS	Multicriteria detector	ED300	0832-CPR-F1151
32	INIM ELECTRONICS	I/O device with short circuit isolator	EM312SR	0832-CPR-F1245
33	INIM ELECTRONICS	I/O device with short circuit isolator	EU311	0832-CPR-F1246
34	INIM ELECTRONICS	I/O device with short circuit isolator	EM344R	0832-CPR-F0445
35	INIM ELECTRONICS	I/O device with short circuit isolator	EM344S	0832-CPR-F0444
36	INIM ELECTRONICS	Input device with short circuit isolator	EM340	0832-CPR-F0446
37	INIM ELECTRONICS	Output device with short circuit isolator	EM304S	0832-CPR-F0447
38	INIM ELECTRONICS	Output device with short circuit isolator	EM304R	0832-CPR-F0448
39	INIM ELECTRONICS	Manual call point with short circuit isolator	EC0020	0832-CPR-F0443
40	INIM ELECTRONICS	Power supply equipment	SPS24060S	0051-CPR-0434
41	INIM ELECTRONICS	Power supply equipment	SPS24160S	0051-CPR-0433
42	INIM ELECTRONICS	Sounders device with short circuit isolator	ESB1010	0051-CPR-1317
43	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ESB1020	0051-CPR-1316
44	INIM ELECTRONICS	Sounders device with short circuit isolator	ESB1030	0051-CPR-1317
45	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ESB1050	0051-CPR-1316
46	INIM ELECTRONICS	Sounders device with short circuit isolator	ES1010	0051-CPR-1317
47	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES1020	0051-CPR-1316
48	INIM ELECTRONICS	Sounders device with short circuit isolator	ES1030	0051-CPR-1317
49	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES1050	0051-CPR-1316
50	INIM ELECTRONICS	Sounders device with short circuit isolator	ES2010RE	0051-CPR-1317
51	INIM ELECTRONICS	Sounders device with short circuit isolator	ES2010WE	0051-CPR-1317
52	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES2020RE	0051-CPR-1316
53	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES2020WE	0051-CPR-1316
54	INIM ELECTRONICS	Sounders device with short circuit isolator	ES2030RE	0051-CPR-1317
55	INIM ELECTRONICS	Sounders device with short circuit isolator	ES2030WE	0051-CPR-1317
56	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES2050RE	0051-CPR-1316
57	INIM ELECTRONICS	Sounders and visual alarm device with short circuit isolator	ES2050WE	0051-CPR-1316

<u>Conventional devices</u>				
N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
58	INIM ELECTRONICS	Sounders device	ISB1010	0051-CPR-1319
59	INIM ELECTRONICS	Sounders and visual alarm device	ISB1020	0051-CPR-1318
60	INIM ELECTRONICS	Sounders device	ISB1030	0051-CPR-1319
61	INIM ELECTRONICS	Sounders and visual alarm device	ISB1050	0051-CPR-1318
62	INIM ELECTRONICS	Smoke detector	ID100	0832-CPR-F1152
63	INIM ELECTRONICS	Heat detector	ID200	0832-CPR-F1243
64	INIM ELECTRONICS	Multicriteria detector	ID300	0832-CPR-F1153
65	INIM ELECTRONICS	Manual call point	IC0020	0832-CPR-F0442
66	INIM ELECTRONICS	Ceiling siren	IS1010	0051-CPR-1319
67	INIM ELECTRONICS	Sounder and visual alarm device	IS1020	0051-CPR-1318
68	INIM ELECTRONICS	Sounder device	IS1030	0051-CPR-1319
69	INIM ELECTRONICS	Sounder and visual alarm device	IS1050	0051-CPR-1318
70	INIM ELECTRONICS	Sounder device	IS2010RE	0051-CPR-1319
71	INIM ELECTRONICS	Sounder device	IS2010WE	0051-CPR-1319
72	INIM ELECTRONICS	Sounder and visual alarm device	IS2020RE	0051-CPR-1318
73	INIM ELECTRONICS	Sounder and visual alarm device	IS2020WE	0051-CPR-1318
74	INIM ELECTRONICS	Sounder device	IS2030RE	0051-CPR-1319
75	INIM ELECTRONICS	Sounder device	IS2030WE	0051-CPR-1319
76	INIM ELECTRONICS	Sounder and visual alarm device	IS2050RE	0051-CPR-1318
77	INIM ELECTRONICS	Sounder and visual alarm device	IS2050WE	0051-CPR-1318
78	SAFETY TECHNOLOGY INTERNATIONAL	Manual call point	WRP2-R-01	0359-CPR-00439
79	THE FIRE BEAM COMPANY	Smoke detectors – Line detectors using an optical beam	THEFIREBEAM	0786-CPD-20241
80	TEXECOM	Sounder device	PBS-0003	0832-CPD-0453
81	TEXECOM	Sounder device	SONOS DC SOUNDERS [PSS-0020 (PSO-0003 and PSS-0084)]	0832-CPR-F1923
82	TEXECOM	Sounder device	SONOS DC SOUNDERS [PSS-0050 (PSO-0007 and PSS-0089)]	0832-CPR-F1923
83	TEXECOM	Sounder device	SONOS DC SOUNDERS [PSS-0003 (PSO-0001 and PSS-0084)]	0832-CPR-F1923
84	TEXECOM	Sounder and visual alarm device	ESCA4000R (with PSO-0017)	0832-CPR-F0010
85	TEXECOM	Sounder and visual alarm device	ESCA4000R (with PSO-0001)	0832-CPR-F0010
86	TEXECOM	Sounder and visual alarm device	ESCA3000R (with PSO-0017)	0832-CPR-F0008

N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
87	TEXECOM	Sounder and visual alarm device	ESCA4000W (with PSO-0017)	0832-CPR-F0010
88	TEXECOM	Sounder and visual alarm device	ESCA3000W (with PSO-0017)	0832-CPR-F0008
89	TEXECOM	Visual alarm device	ESBA4000R (with PSO-0017)	0832-CPR-F0009
90	TEXECOM	Visual alarm device	ESBA3000R (with PSO-0017)	0832-CPR-F0007
91	TEXECOM	Visual alarm device	ESBA4000R (with PSO-0001)	0832-CPR-F0009
92	TEXECOM	Visual alarm device	ESBA3000R (with PSO-0001)	0832-CPR-F0007
93	TEXECOM	Sounder device	TAA-0007 6"	0832-CPD-0760
94	TEXECOM	Sounder device	TAA-0017 6"	0832-CPD-0959
95	SYNAPS TECHNOLOGY	Sounder and visual alarm device	LF24W	1328-CPR-0427
96	SYNAPS TECHNOLOGY	Sounder device	LF20W	1328-CPR-0584
97	COOPER FULLEON	Sounder device	SYHO/C	0832-CPD-0142
98	COOPER FULLEON	Sounder device	SYHO/WP	0832-CPD-0142
<b><u>Addressable devices</u></b>				
99	ARGUS SECURITY	Smoke detector with short circuit isolator	V100	0832-CPD-1066
100	ARGUS SECURITY	Multicriteria detector with short circuit isolator	V200	0832-CPD-1067
101	ARGUS SECURITY	Heat detector with short circuit isolator	V350	0832-CPD-1065
102	ARGUS SECURITY	Manual call point with short circuit isolator	VCP100	0832-CPD-1059
103	ARGUS SECURITY	I/O device with short circuit isolator	VMMIC100	0786-CPD-21212
104	ARGUS SECURITY	I/O device with short circuit isolator	VMMIC120	0786-CPD-21214
105	ARGUS SECURITY	I/O device with short circuit isolator	VMMI100	0786-CPD-21210
106	ARGUS SECURITY	I/O device with short circuit isolator	VMMC100	0786-CPD-21211
107	ARGUS SECURITY	I/O device with short circuit isolator	VMMC120	0786-CPD-21213
108	ARGUS SECURITY	I/O device with short circuit isolator	VMIC100	0786-CPD-21189
109	ARGUS SECURITY	I/O device with short circuit isolator	VMIC120	0786-CPD-21187
110	ARGUS SECURITY	I/O device with short circuit isolator	VMI100	0786-CPD-21190
111	ARGUS SECURITY	I/O device with short circuit isolator	VMC100	0786-CPD-21188
112	ARGUS SECURITY	I/O device with short circuit isolator	VMC120	0786-CPD-21186
113	ARGUS SECURITY	Sounder with short circuit isolator	ALWS-MOD+CWS100	0832-CPR-F0992
114	ARGUS SECURITY	Sounder and visual alarm device with short circuit isolator	ALWS-MOD+CWS100-AV	0832-CPR-F0993
115	ARGUS SECURITY	Wire to Wireless translator (I/O device with short circuit isolator)	VW2W100	0832-CPD-1071
116	ARGUS SECURITY	I/O device	SGWE100	0832-CPD-1690
117	ARGUS SECURITY	Wireless smoke detector	SG100	0832-CPD-1069
118	ARGUS SECURITY	Wireless multicriteria detector	SG200	0832-CPD-1070

N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
119	ARGUS SECURITY	Wireless heat detector	SG350	0832-CPD-1068
120	ARGUS SECURITY	Wireless manual call point	SGCP100	0832-CPD-1683
121	ARGUS SECURITY	Wireless I/O device	SGMCB200	0832-CPR-F0690
122	ARGUS SECURITY	Wireless I/O device	SGMI200	0832-CPR-F0691
123	ARGUS SECURITY	Wireless sounder device	SGWS-MOD+CWS100	0051-CPR-0464
124	ARGUS SECURITY	Wireless sounder and visual alarm device	SGWS-MOD+CWS100-AV	0051-CPR-0465
125	ARGUS SECURITY	Wireless sounder device	SGRBS100	0832-CPD-1684
126	ARGUS SECURITY	Wireless sounder device	SGRBS100-AV	0832-CPD-1685
127	APOLLO FIRE DETECTORS	Smoke detector	55000-885	0832-CPR-F1030
128	APOLLO FIRE DETECTORS	Heat detector	55000-401	0832-CPR-F1724
129	APOLLO FIRE DETECTORS	Smoke detector	55000-620	0832-CPR-F1027
130	APOLLO FIRE DETECTORS	Smoke detector	55000-600	0832-CPR-F1027
131	APOLLO FIRE DETECTORS	Heat detector	55000-400	0832-CPR-F1722
132	APOLLO FIRE DETECTORS	Visual alarm device with short circuit isolator	45681-709	0832-CPR-F0467
133	APOLLO FIRE DETECTORS	Sounder and visual alarm device with short circuit isolator	45681-705	0832-CPR-F0459
134	APOLLO FIRE DETECTORS	Manual call point	55100-905	0832-CPD-0795
135	APOLLO FIRE DETECTORS	Manual call point	55100-908	0832-CPR-F1451
136	APOLLO FIRE DETECTORS	Heat detector	58000-305	0832-CPD-1761
137	APOLLO FIRE DETECTORS	Heat detector	58000-400	0832-CPD-0022
138	APOLLO FIRE DETECTORS	Smoke detector	58000-600	0832-CPR-F1031
139	APOLLO FIRE DETECTORS	Multicriteria detector	58000-700	0832-CPR-F1031
140	APOLLO FIRE DETECTORS	Manual call point with short circuit isolator	58100-908	0832-CPD-0798
141	APOLLO FIRE DETECTORS	Manual call point	58100-910	0832-CPD-0797
142	APOLLO FIRE DETECTORS	Aspirating smoke detector	Discovery ASD-1 Discovery ASD-2	0786-CPR-21340
143	APOLLO FIRE DETECTORS	Sounder with with short circuit isolator	58000-030 58000-040	0832-CPD-2098
144	APOLLO FIRE DETECTORS	Sounder with with short circuit isolator	58000-010 58000-020	0832-CPD-2097
145	APOLLO FIRE DETECTORS	Sounder device	58000-005 58000-007	0832-CPR-F1494
146	APOLLO FIRE DETECTORS	Sounder device with short circuit isolator	45681-702	0832-CPR-F0465
147	APOLLO FIRE DETECTORS	Sounder and visual alarm device with short circuit isolator	58000-700 58000-701	0832-CPR-F0457
148	APOLLO FIRE DETECTORS	Heat detector	55000-440	0832-CPD-0311
149	APOLLO FIRE DETECTORS	Smoke detector	55000-640	0832-CPR-F1028

N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
150	APOLLO FIRE DETECTORS	Manual call point	55200-940	0359-CPR-00188
151	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11016-APO	0832-CPD-0032
152	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11003-APO	0832-CPD-0031
153	APOLLO FIRE DETECTORS	Smoke detector	ORB-OP-12001-APO	0832-CPR-F1350
154	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11167-APO	0832-CPD-0450
155	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11004-APO	0832-CPD-0032
156	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11013-APO	0832-CPD-0029
157	APOLLO FIRE DETECTORS	Smoke detector	ORB-OH-13001-APO	0832-CPD-0036
158	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11014-APO	0832-CPD-0030
159	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11166-APO	0832-CPD-0450
160	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11018-APO	0832-CPD-0034
161	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11001-APO	0832-CPD-0029
162	APOLLO FIRE DETECTORS	Smoke detector	ORB-OP-12003-APO	0832-CPR-F1350
163	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11015-APO	0832-CPD-0031
164	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11002-APO	0832-CPD-0030
165	APOLLO FIRE DETECTORS	Heat detector	ORB-HT-11006-APO	0832-CPD-0034
166	APOLLO FIRE DETECTORS	Smoke detector	ORB-OH-13003-APO	0832-CPD-0036
167	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA6700-100	0832-CPR-F1319
168	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-760	0832-CPR-F1448
169	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-845	0832-CPD-0868
170	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA4700-100	0832-CPR-F1316
171	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA4700-302	0832-CPR-F1316
172	APOLLO FIRE DETECTORS	I/O device	55000-822	0832-CPD-0857
173	APOLLO FIRE DETECTORS	I/O device	55000-875	0832-CPD-0860
174	APOLLO FIRE DETECTORS	I/O device	55000-182	0832-CPD-0852
175	APOLLO FIRE DETECTORS	I/O device	55000-856	0832-CPD-0859
176	APOLLO FIRE DETECTORS	I/O device	55000-855	0832-CPD-0859
177	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-843	0832-CPD-0867
178	APOLLO FIRE DETECTORS	I/O device	55000-797	0832-CPD-0853
179	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-812	0832-CPD-0865





## ANNEX 1

REGISTRATION NO. : 1342

N.	MANUFACTURER	PRODUCT DESCRIPTION	TYPE	CERTIFICATE N.
180	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-852	0832-CPD-0871
181	APOLLO FIRE DETECTORS	I/O device	55000-803	0832-CPD-0854
182	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	55000-847	0832-CPR-F0092
183	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA4700-300	0832-CPR-F1316
184	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA4700-102	0832-CPR-F1316
185	APOLLO FIRE DETECTORS	Short circuit isolator	55000-802	0832-CPD-0844
186	APOLLO FIRE DETECTORS	I/O device with short circuit isolator	SA4700-103	0832-CPR-F1318