



Certificate of Continued Compliance 12229034/AA/06



Issued	27-06-2024	Replaces	12229034/AA/05
Expiry date	27-06-2028	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Magnetic Surface Contact
Trademark:	CQR Maximal
Type designation:	SC570*/G3/EN
Hardware / Software:	V1.0 / N/A

Placed on the market under the name or trademark of:

Name of the manufacturer:	CQR Security
Address:	125 Pasture Road
City:	CH46 4TH Moreton
Country:	UNITED KINGDOM

This certificate is granted to:

Name of the certificate holder:	CQR Security
Address:	125 Pasture Road
City:	CH46 4TH Moreton
Country:	UNITED KINGDOM

Ron Scheepers
Managing director

This certificate has THREE Annexes.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

"" in the type designation SC570*/G3/EN is for the color indication, for example:

WH = White

BR = Brown

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 20103514800, 09 August 2011

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-6

September, 2008

Applied Standards

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2+A3

June, 2020

The product as described in this certificate includes the following type designations

- Product description: Magnetic Surface Contact
- Trademark: CQR Maximal
- Type designation: SC570*/G3/EN
- Hardware version: V1.0
- Software version: N/A